



ITC Limited

Paperboards & Specialty Papers Division

Unit – Tribeni

WATER MANAGEMENT


CII-SOHRABJI GODREJ GREEN BUSINESS CENTRE

16th – 17th December 2008

Unit Profile

- **A Specialty Paper Mill**
- **Three Paper Machines**
- **Production 2007-08: 23387 MT**
- **Annual Turnover = Rs. 1937 Million**
- **Certified ISO 9001, 14001 and OHSAS 18001**

Organisation Structure



Source of Water

- f 17 Nos. of Borewells located within Mill and Estate Area
- f Sink Depth of 600 ft below ground level
- f Tapping is done at a depth of 350-550 ft


Water Balance

Area	Quantity m ³ /day
Average daily consumption	5959
Paper Machine 1	1311
Paper Machine 3	2169
Paper Machine 4	1740
DM Plant	345
DIW & ETP	110
Chemical Kitchen	120
Mill Drinking Water	164

Fresh Water Consumption


(April – March)	Quantity , m3		Production in Tonnes	Specific water consumption, m3/MT
	Industrial	Domestic		
2004-05	2532351	132168	23667	107
2005-06	2516196	1269674	24024	105
2006-07	2395356	1150734	24250	99
2007-08	2114830	1131597	23387	90

Fresh Water Consumption



With continuous efforts and several fresh water saving initiatives implemented, we have reached this position.

Fresh Water Consumption



Fresh Water Consumption

Benchmarking

Tribeni Mill	National Benchmark	International Benchmark	CPCB Norms
90 m ³ /T	Not Available	100 m ³ /T	150 m ³ /T (w.r.t waste water norms of 120)

Best Available References of European Countries from the "BREF Pulp and Paper", electronic adaptation of the European reference document on Best Available Techniques (in the slant of reducing the aggressions to man and environment) in the Pulp and Paper manufacturing industry.

Implemented Projects 07-08

Scheme-1: Recirculation of Fresh Water from Overhead Tank for Compressor cooling



Implemented Projects 07-08

Scheme 1

Old System:

F/water requirement 30 m³/hr .

Water sent back to Over head Tank : Nill

Actual cooling Water consumed : 30m³/hr

New System:

F/water requirement 30 m³/hr .

Water sent back to Overhead Tank : 30 m³/hr

Actual cooling Water consumed : Nil

Savings : 237600 m³ /year

Investment Rs.0.2 Lakhs

Implemented Projects 07-08

Scheme-2: Reduction of sealing water in Couch of PM4 by use of Anti friction bearing



Savings : 31680 m³ /year

Investment Rs. 9 Lakhs

Implemented Projects 07-08

Scheme3: Refurbishing of PM4 steam & condenser circuit



Implemented Projects 07-08

Scheme3: Refurbishing of PM4 steam & condenser circuit

Old System:

Steam requirement : 110 TPD

Condensate recovery : 39 TPD

Water requirement : 71 TPD

New System:

Steam requirement : 80 TPD

Condensate recovery : 56 TPD

Water requirement : 21 TPD

Water saving : 50 TPD

(This saving would come in DM water)

Savings : 49500 m³ / year (DM water)

Investment Rs. 120 Lakhs

Implemented Projects 07-08

Scheme5: Sequencing of Coloured Laminating Grade making on PM4

Grade change in Colour laminating grades is associated with lot of water for cleaning & flushing the system. T PM team has come together to reorganize making schedule with in-depth R& D inputs to avoid water usage during many grade changes

Savings : 12000 m³ / year

Investment : Nil

Implemented Projects 07-08

Scheme 6: Use of New Generation CentriCleaner system on PM1

Picture before modification
Water requirement : 6m³/hr



Picture after modification
Water requirement : 4m³/hr



Savings 15840 m³ / year

Investment Rs.28 Lakhs

Implemented Projects 07-08

Scheme 7:

Reduction of leakage of Gland sealing water through use of Mechanical seals

Savings : 15840 m³ / year

Investment Rs. 24 Lakhs

Implemented Projects 07-08

Scheme 8:

Use of highly efficient imported Vacuum Pumps requiring less sealing water

Before Modernisation



After Modernisation



Savings : 23760 m³ / year

Investment Rs.57 Lakhs

Implemented Projects 07-08

Scheme 9:

Reduction in consumption of Make up water in Cooling Tower by improving COC



Implemented Projects 07-08

Scheme 9:

Reduction in consumption of Make up water in Cooling Tower by improving COC

Old System:

For TG2

Evaporation loss: 11 m³/hr

Blow down : 27.5 m³/hr

Total make up water : 38.5 m³/hr

For TG3

Evaporation loss: 14.7 m³/hr

Blow down : 36.7 m³/hr

Total make up water : 51.4 m³/hr

Total make up water reqd.: 89.9 m³/hr

New System:

For TG2

Evaporation loss: 11 m³/hr

Blow down : 5.5 m³/hr

Total make up water : 16.5 m³/hr

For TG3

Evaporation loss: 14.7 m³/hr

Blow down : 7.4 m³/hr

Total make up water : 22 m³/hr

Total make up water reqd.: 38.5 m³/hr

Savings : 50 m³ / hour

Investment Rs. 40 Lakhs

Implemented Projects 07-08

Scheme 10:


Introduction of Reverse Osmosis system in PM1



Savings : 39600 m³ / year

Investment Rs.40 Lakhs

Waste Water Discharge



With continuous efforts in maximising process water recycling we have reduced below 50% of CPCB norms.

Waste Water Discharge

Waste Water Discharge - Benchmarking

Tribeni Mill	National Benchmark	International Benchmark	CPCB Norms
615 m³/T	Not Available	60 m³/T	120 m³/T

Best Available References of European Countries from the "BREF Pulp and Paper", electronic adaptation of the European reference document on Best Available Techniques (in the slant of reducing the aggressions to man and environment) in the Pulp and Paper manufacturing industry.

The Road Map towards Zero Discharge

3-step process:

Implementation of Future Fresh Water Conservation Projects

Closing the Water Loop with reuse of Mill

Treated Water

Continuous Monitoring and Control to sustain
the System

Monitoring



- f All fresh water consuming areas are provided with water flow meters connected to DCS system.
- f Daily, weekly and monthly MIS reports contain the fresh water consumption figures.
- f Monitoring is done online, by the respective utilities and paper machine shift incharges.
- f Specific Key Focus Areas are predefined for respective managers as a part of their annual appraisal system for Water Conservation Measures and Monitoring